

Assessment Results Exceedance Table

Below is the summary table of exceedances (> 15 ppb) by location. Exceedances were identified only in samples collected from sinks; no drinking fountain samples had a concentration of lead above 15 ppb. In summary:

- ◇ None (0%) of the 8 samples from the Westorchard Elementary School exceeded 15 ppb.
- ◇ None (0%) of the 4 samples from the Douglas Grafflin Elementary School exceeded 15 ppb.
- ◇ None (0%) of the 8 samples from the Roaring Brook Elementary School exceeded 15 ppb.
- ◇ None (0%) of the 24 samples from the Seven Bridges Middle School exceeded 15 ppb.
- ◇ 6 (18.8%) of the 32 samples from the Robert Bell Middle School exceeded 15 ppb.

Robert Bell Middle School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
12/2/16	RBMS-112A	3 rd	Sink #6 in Room 348	2270
12/2/16	RBMS-113A	3 rd	Sink #3 in Room 346	1140
12/2/16	RBMS-114A	3 rd	Sink #6 in Room 346	53.0
12/2/16	RBMS-115A	3 rd	Sink #4 in Room 344	60.9
12/2/16	RBMS-116A	3 rd	Sink #5 in Room 344	19.9
12/2/16	RBMS-119A	3 rd	Sink #7 in Room 340 Storage Closet	36.6